

Certificate of Constancy of Performance



0359-CPR-00241

Appendix to Certificate of Constancy of Performance 0359-CPR-00241

The details and condition of use for the LDA Audio Tech Wall Mount Loudspeaker, placed on the market by:

LDA AUDIO TECH (LDA AUDIO Y VIDEO PROFESIONAL S.L.)
Parque Tecnológico Andalucía, C/Severo Ochoa 31, 29590 Malaga (SPAIN)

To be used in accordance with the supplier's installation instructions and in conjunction with the following bases, ancillaries, sounder tones and sensitivity settings (*where applicable*):

Products compliant with EN54-24:2008

| Variant | Description |
|--------------|---|
| LDADS60TNS01 | 4" Wall Mount Loudspeaker with Metal Back Box |

Conditions of use:

Suitable for indoor applications

General Notes:

1. Tested under Intertek project number 12057984 and 101461404.
2. No CE or other type approval is made or inferred outside of the attestation of conformity and the product performance as stipulated on this certificate.

Intertek Testing & Certification Limited, Cleeve Road, Leatherhead, Surrey, KT22 7SB
Tel: + 44 (0)1372 370900, Fax: +44 (0)1372 370977, E-mail: cpd.uk@intertek.com

0359-CPR-00241
Issue 1

www.intertek.com

Registered No 3272281 Academy Place, 1-9 Brook Street, Brentwood, Essex,
CM14 5NQ, United Kingdom

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate and then only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.

Certificate of Constancy of Performance



0359-CPR-00241

Appendix to Certificate of Constancy of Performance 0359-CPR-00241 (continued)

| <i>Table of performance for EN54-24:2008</i> | | | |
|--|--------------------|--------------------------|--------------|
| Harmonised technical specification | | | |
| Essential characteristics | Performance | Clauses | Notes |
| Performance under fire condition. | Pass | 4.2, 5.2, 5.3, 5.4, 5.5 | a |
| Operational reliability | Pass | 4.3, 4.4, 4.5, 5.6, 5.18 | b |
| Durability of operational reliability: temperature resistance | Pass | 5.7, 5.8, 5.9 | b, c |
| Durability of operational reliability: humidity resistance | Pass | 5.10, 5.11, 5.12 | b, c |
| Durability of operational reliability: corrosion resistance | Pass | 5.13 | |
| Durability of operational reliability: impact and vibration resistance | Pass | 5.14, 5.15, 5.16, 5.17 | |
| <i>Notes:</i> | | | |
| a. <i>The products covered by this standard are assumed to enter the alarm condition, in an event of fire, before the fire becomes so large as to affect their functioning. There is therefore no requirement to function when exposed to direct attack from fire.</i> | | | |
| b. <i>For Clauses 5.7, 5.9, 5.10 and 5.18, Type A conditioning was applied.</i> | | | |
| c. <i>Clauses 5.8 and 5.12 are not applicable to Type A loudspeakers.</i> | | | |

Intertek Testing & Certification Limited, Cleeve Road, Leatherhead, Surrey, KT22 7SB
Tel: + 44 (0)1372 370900, Fax: +44 (0)1372 370977, E-mail: cpd.uk@intertek.com

0359-CPR-00241
Issue 1

www.intertek.com

Registered No 3272281 Academy Place, 1-9 Brook Street, Brentwood, Essex,
CM14 5NQ, United Kingdom

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate and then only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.